

Don Johnson

From: Robert Craig
Sent: Friday, July 11, 2003 3:59 PM
To: Don Johnson
Cc: Roland Bartl
Subject: RE: Ellsworth Village 40B
Importance: High

Don: Just got this around 2:00 this afternoon and then became tied up at a three car accident on Great Road. I gave some verbal comments to Kristen in planning. They are as follows: My major concern is a single access for a 60 unit complex. In addition I have no information on water supply plans, adequacy of water supply for fire protection, hydrants, fire alarm, road grades, etc. As shown in this conceptual plan, turning radii appears to be adequate. That is all I can comment on at this point. Bob

-----Original Message-----